

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: T 1343
Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

IMMERGAS S.p.A
Via Cisa Ligure 95, 42041 Brescello RE, Italija /Italy

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 1343

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Izjava proizvođača / Manufacturer's statement;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 0538 /
Test report by IMP-CGT-LAB No. T 0538.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

GASNI KOTAO
GAS BOILER

proizveden od /
manufactured by :

IMMERGAS S.p.A
Via Cisa Ligure 95, Brescello, Italija /Italy

oznaka - tip - serija /
mark - type - series :

IMMERGAS EOLO STAR 24 3 E

vrsta/type: C_{12(x)}, C_{32(x)}
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document :

SRPS EN 483:2010; SRPS EN 625:2011;

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim
kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection
until the date :

01.10.2018.

izdat od / issued by :

UKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date:

M.P. /
S.P.

Beograd, 01.10.2013.

Kristina Potković, dipl. ing.

Ime , Prezime / Name , Surname



ATC
06-010

АКРЕДИТОВАНА
КОНТРОЛНА
ОРГАНИЗАЦИЈА
SRPS ISO/IEC 17020:2002

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: T 1343

Strana / Page: 2/2

Prilog A /

Annex A

oznaka - tip - serija /
mark - type - series :

IMMERGAS EOLO STAR 24 3 E

vrsta/type: C_{12(x)}, C_{32(x)}
kategorija/category: II_{2H3B/P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
IMMERGAS EOLO STAR 24 3 E	Q _n =7,6÷25,5 kW P _n =6,8÷23,8 kW 2H: p=20 mbar - 3B/P: p=29/37 mbar PMS=3 bar, Ts=90° C, PMW= 10 bar 230V, 50 Hz	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)

Inspection certificate

Sertifikat o kontrolisanju